



# MET-CHEM LABORATORIES

"CHINTAMANI" PLOT NO. 10, PARSHURAMNAGAR SOCIETY, SAYAJI GUNJ, VADODARA-20. • PH.: (0265) 2361314/19 Mo.:9427611654  
E-mail : sgirish13@gmail.com • Web site : www.met-chemlaboratories.com

Multi Kilfire P. Ltd.  
4, Amin Industrial Estate,  
Gorwa Road,  
Vadodara - 39

## TEST CERTIFICATE

Report No : 1433


Date : 02/03/2016

( THIS SAMPLE/S WAS/WERE NOT DRAWN BY US )

### Test Results :

### ANTI RODENT TEST

- 1. Sample Description : KF-600 Fire Retardant coating Compound applied on Cable to a DFT of 1.8mm to 2.0mm
- 2. Test Description : Cable piece coated with KF-600 placed in a cage for 5 days containing Rats & Mice without food and observation made.
- 3. Result : No bites / Eating marks observed on coated piece of cable.



For MET-CHEM Laboratories

ANY REPRODUCTION OR XEROX COPY IN PART OR FULL IS NOT VALID UNLESS ATTESTED RESULTS PERTAIN TO THE SAMPLE (S) ONLY. SAMPLE NOT DRAWN BY US. LIABILITY FOR RETURN OF THE SAMPLE CEASES AFTER A FORTNIGHT.

**CHEMICAL TESTING OF :** All Ferrous, Non-Ferrous Metals, Ferro-Alloys, Ores, Coal/ Coke Testing, Organic & Inorganic Chemicals, Catalyst Test, Composite & Indigenisation of Materials Test, Water, Acid, Wood testing.

**NDT TESTING :** Magnetic Particle Test, Ultrasonic Flaw Detection and Thickness Surveys, etc.

**PHYSICAL TEST :** Physical (Tensile / Impact / Hardness, Micro / Macro Etc.) Sieve Analysis for various Materials etc.

**OTHER TEST :** Any type of Third Party Inspection, Corrosion tests, Residual Life Assessment etc.

