



BHARAT HEAVY ELECTRICALS LTD.

(A Government of India Undertaking)

CORPORATE QUALITY INSPECTION REPORT

The release of this CQ-IR does not relieve the Supplier of responsibilities under the terms and conditions of the contract. This CQ-IR is released without prejudice to the purchaser's right under the terms and conditions of the contract. This document is not an authorisation for despatch. Clearance for Despatch to be obtained by Supplier from the Purchasing Division.

Supplier Ref No.	G0046	IRFile No. / Call no	VASD180212 / 0
Supplier	MULTI KILFIRE PVT LTD	CQ-Centre :	BVI-VADDODARA-VVA
Purchasing Unit / Agency :	PE AND SD HYDERABAD	PO STATUS	OPEN
BHEL PO No.	T715A00311	BHEL PO date	18/07/2018
BHEL LOI No.		BHEL LOI date	
Project Name	RINL VIZAG	Package Name /System	FIRE BREAK COATING
Call NO	0	Call-Status	CLOSED
Inspection Start Date	06/08/2018	Inspection End Date	06/08/2018

PO / BOM / BBU Item No	Item / Component Description	Docs	Quantity		Offd	Sample Inspected	Appd Code	Disp Code	Cum. Acctd
			Units	Reqd					
0010	FIRE BREAK COATING	docs	SOM	400	400	0	400	ACCEPTED	400

Documents Used as Annexure

Page 1 of total (1) pages

Remarks

INSPECTION CARRIED OUT BASED ON PO, QAP NO. SMQP/PE.EP/058/1, DT.28.12.2015, BHEL SPEC PY55138, REV-00. (1) REVIEWED FAME SPREAD TEST REPORT - FOUND IN ORDER. (2) REVIEWED OF FLAME PROPAGATION TEST REPORT - FOUND IN ORDER. (3) REVIEWED OF CIRCUIT INTEGRITY TEST REPORT - FOUND IN ORDER. (4) REVIEWED OF LOI TEST REPORT - FOUND IN ORDER. (5) REVIEWED OF OTHER TEST AS PER UL 3971 TEST REPORTS - FOUND IN ORDER. MATERIAL BATCH - JULY 18, FIRE RETARDANT COATING KF 600. 20 KG EACH X 44 NOS DRUM.

Enclosures: CQIR WITH DOCUMENTS, PHOTOGRAPHS

NAME	RINL VIZAG	HITESH BHAVSAR	MULTI KILFIRE PVT LTD
	Customer / Consultant	BVI-VADDODARA-VVA, BHEL	Supplier
			Sub-Supplier

Handwritten signature: H-V
 Date: 06/08/18



Close