

BHARAT HEAVY ELECTRICALS Ltd.

(A Government of India Undertaking)

CORPORATE QUALITY INSPECTION REPORT

The release of this CQ-IR does not relieve the Supplier of responsibilities under the terms and conditions of the contract. This CQ-IR is released without prejudice to the purchaser's right under the terms and conditions of the contract. This document is not an authorisation for despatch. **Clearance for Despatch to be obtained by Supplier from the Purchasing Division.**

Supplier Ref No.	MKPL/12-13/LM/008	IRFile No. / Call no	LVAPM120021 / 0
Supplier	MULTI KILFIRE PVT LTD	CQ-Centre :	LVA-LLOYDS-VADODARA
Purchasing Unit / Agency :	PEM, NOIDA	PO STATUS	OPEN
BHEL PO No.	PW/PE/PG/BTN/P-298/12	BHEL PO date	16/08/2012
BHEL LOI No.		BHEL LOI date	
Project Name	2X250 MW LEHRA MOHABBAT TPP	Package Name /System	FIRE SEALING SYSTEM
Call NO	0	Call-Status	CLOSED
Inspection Start Date	31/08/2012	Inspection End Date	31/08/2012

PO/ BOM/ BBU Item No	Item/ Component Description	Docs	Quantity Units	Reqd	Offd	Sample Inspected	Appd Disp Code	Cum. Acptd
1	COATING ON CABLES - KF 600	docs	SQ.M.	500	500	500	500	ACCEPTED 500
2 SAMPLES SELECTED FOR TESTING FROM THE LOT								

Documents Used as Annexure

Page 1 of total (1) pages

REMARKS: VERIFIED APPEARANCE, WITNESSED VERIFICATION OF PH VALUE AND SPECIFIC GRAVITY VALUE. VERIFIED MANUFACTURER'S INSPECTION RECORDS AS PER QAP NO KF/QAP/001

ENCLOSURES: TEST REPORTS

NAME	PUNJAB STATE ELECTRICITY BOARD PATIALA	RAJA CHADHA	MULTI KILFIRE PVT LTD
Customer / Consultant	LVA-LLOYDS-VADODARA , BHEL	Supplier	Sub-Supplier



Close