



MET-CHEM LABORATORIES

"CHINTAMANI" PLOT NO. 10, PARSHURAMNAGAR SOCIETY, SAYAJI GUNJ,
VADODARA-20. • PH.: (0265) 2361314/19 Mo.:9427611654
E-mail : sgirish13@gmail.com • Web site : www.met-chemlaboratories.com

Multi Kilfire P. Ltd.
4, Amin Industrial Estate,
Gorwa Road,
Vadodara - 16

TEST CERTIFICATE

Report No : 1360

Date : 17/02/2016

(THIS SAMPLE/S WAS/WERE NOT DRAWN BY US)

Test Results :

: FIRE RETARDANT COATING KF-600 MKPL MAKE FOR ELECTRICAL CABLE :

1. Method : Flame Propagation IEC 332-3 category 'A'
2. Description fo Sample : 1) Coated 4 nos. Dia.50mm & Length 3.5 meter each.
2) Coating thickness :DFT- 1.8mm to 2.0 mm
3. Duration : 40 Minutes & 1050 Deg.cent +/- 20 Deg.cent.
4. Observation : Charred or affected average length was 1.1 meter.
5. Standard : IEC 332-3 charred or affected length2.5 meter max.
6. Result : Test found Satisfactory.

For MET-CHEM Laboratories

ANY REPRODUCTION OR XEROX COPY IN PART OR FULL IS NOT VALID UNLESS ATTESTED RESULTS PERTAIN TO THE SAMPLE (S) ONLY. SAMPLE NOT DRAWN BY US, LIABILITY FOR RETURN OF THE SAMPLE CEASES AFTER A FORTNIGHT.

CHEMICAL TESTING OF : All Ferrous, Non-Ferrous Metals, Ferro-Alloys, Ores, Coal/ Coke Testing ,Organic & Inorganic Chemicals , Catalyst Test, Composite & Indigenisation of Materials Test, Water, Acid ,Wood testing.

NDT TESTING : Magnetic Particle Test, Ultrasonic Flaw Detection and Thickness Surverys, etc.

PHYSICAL TEST : Physical (Tensile / Impact / Hardness, Micro / Macro Etc.) Sieve Analysis for various Materials etc.

OTHER TEST : Any type of Third Party Inspection, Corrosion tests, Residual Life Assesment etc.

