

MINUTES OF MEETING HELD BETWEEN M/s MULTI KIL FIRE PVT. LTD., VADODARA AND M/s KPCL AT RTPS, SHAKTINAGAR ON 22.10.2016 REGARDING SEALING OF CABLE PENETRATION CUTOUTS IN UNIT-5, 6&7 AT RTPS

MEMBERS PRESENT:

M/s. RTPS, KPCL, SHAKTINAGAR

- 1) Sri B.H. Ramachandra, EE(LT-2)
- 2) Sri Laxman Saibannavar, AE(E)



M/s. MULTI KIL FIRE PVT. LTD., VADODARA

- 1) Sri Ramasingh, Supervisor


A work order was placed on M/s. Multi Kil Fire Pvt. Ltd., Vadodara, for the Sealing of Cable penetration cutouts in Unit-5, 6&7 at RTPS vide work order No. EELT-2/WO/ U-5,6,&7/Cables/305 dated 07.10.2016.

As per the Work order, the firm has supplied KF-604 fire stop barrier and installed covering 40 sq.m area in feeder floor & 10.5M El. Cable gallery area of Unit-5,6&7. The work has been completed satisfactorily on 22/10/2016 by M/s Multi Kil Fire Pvt. Ltd., Vadodara.

for RTPS/KPCL

- 
1) Sri B.H. Ramachandra, EE(LT-2)
- 
2) Sri Laxman Saibannavar, AE(E)

for M/s. Multi Kil Fire Pvt. Ltd., Vadodara

- 
1) Sri Ramasingh, Supervisor