



44

01.03.2002

WORK COMPLETION CERTIFICATE

This is to certify that M/s Muttkill fire Pvt Ltd had completed installation of fire barrier jobs as per our order no 5300004451 dtd 31.07.2001 at various places for powerhouse as per details given bellow.

A : Jobs

- (1) 125 sq. mtrs of fire barriers at Sub-stations.
- (2) Sealing of 10 no's U/G pipe sleeves with compound.

B : Locations :

- 1) New powerhouse sub station all transformer cabins wall openings and out let of cable gallery wall openings.
- 2) Filling fire barrier in pipe at new powerhouse sub station under ground pipes.
- 3) CEHP-1 cable gallery out let wall openings (Total qty : 1)
- 4) CEHP-2 cable gallery out let wall openings (Total qty : 6)
- 5) HPB-3 sub station cable gallery wall openings (Total qty : 7)
- 6) HPB-3 sub station cable gallery floor cut out for transformer cut out openings (Total qty : 19)

For TATA Chemicals limited

TATA CHEMICALS LIMITED

Mithapur Okhamandal Gujarat 361345

Tel (02892) 23207 23225 Fax (02892) 23227 e-mail mithapur_tatachemicals@tata.com

Registered Office Bombay House 24 Homi Mody Street Mumbai 400001