



MET-CHEM LABORATORIES

"CHINTAMANI" PLOT NO. 10, PARSHURAMNAGAR SOCIETY, SAYAJI GUNJ, VADODARA-20. • PH.: (0265) 2361314/19 Mo.:9427611654 E-mail : sgirish13@gmail.com • Web site : www.met-chemlaboratories.com

Multi Kilfire P. Ltd.
4, Amin Industrial Estate,
Gorwa Road,
Vadodara - 39

TEST CERTIFICATE

Report No : 1425


Date : 29/02/2016

(THIS SAMPLE/S WAS/WERE NOT DRAWN BY US)

Test Results :

TEMPERATURE RESISTANCE TEST

- Sample Description** : PVC Electrical cable coated with fire Retardant compound. KF-600 & DFT was 1.8 mm to 2 mm.
- High Temperature test at 85 Deg.C for 268 Hrs.**
Result : No Film Detoriation.
- Low Temperature test at (-) 15 Deg. Cent for 24 Hrs.**
Result : No. Film Detoriation



For MET-CHEM Laboratories

ANY REPRODUCTION OR XEROX COPY IN PART OR FULL IS NOT VALID UNLESS ATTESTED RESULTS PERTAIN TO THE SAMPLE (S) ONLY. SAMPLE NOT DRAWN BY US, LIABILITY FOR RETURN OF THE SAMPLE CEASES AFTER A FORTNIGHT.

CHEMICAL TESTING OF : All Ferrous, Non-Ferrous Metals, Ferro-Alloys, Ores, Coal/ Coke Testing ,Organic & Inorganic Chemicals / Catalyst Test, Composite & Indigenisation of Materials Test, Water, Acid, Wood testing.

NDT TESTING : Magnetic Particle Test, Ultrasonic Flaw Detection and Thickness Surverys, etc.

PHYSICAL TEST : Physical (Tensile / Impact / Hardness, Micro / Macro Etc.) Sieve Analysis for various Materials etc.

OTHER TEST : Any type of Third Party Inspection, Corrosion tests, Residual Life Assesment etc.

