


**PROTOCL FOR ERECTION OF FIRE SEALING COMPOUND & FIRE
RETARDANT CABLE CATING**

AREA / LOCATION:


- TG MCC, APRDS, ER, CCR, 6mtr, AVR ROOM in #3 & #4.
- CPU MCC, SWAS, CPU REGERATION ROOM (Common for both units).

S.NO	DESCRIPTION	OBSERVATION	REMARKS
1	Fire Sealing compound (KF-604) used in each area 100mm Thickness for sealing of the wall openings for entries of cables tray/ cables	checked ok	
2	Fire retardant cable coating/painting (KF-600) used in each area of 4 coating.	checked ok	

M/s ARIES


K. Srinivasan
22.01.19


M/s CINAICO


22.01.2019

M/s Multikil Fire Pvt. Ltd.


Ravi Srinivas

M/s MEI


22.01.19
CR. Magan