

Minutes of Meeting held between M/s Multicle Fire Pvt. Ltd. And JSPL on dt.  
29.03.2012 regarding Fire coating work at MRSS#1, JSPL, Raigarh.

Members Present

**JSPL**

Mr. Ravish Ranjan  
Mr. K.C. Singh Shee

**M/s Multicle Fire Pvt. Ltd.**

Mr. Ram Singh

With reference to the contract order No. 4512502487 Dt – 02.08.2010, M/s Multicle Fire Pvt. Ltd. has arrived on 20.03.2012 with all tools tackles to carryout the Fire coating work at MRSS#1.

Fire coating in cable job completed on dated 29.03.2012 safely and successfully as per given below:

Sr. No.	Location	Dimension in Mtr.(L*D*No.)	Total area in Mt2	Remarks
1	Cable Celler (o mtr.)	2x0.23x207	95.22	
		2x0.18x9	3.24	
		2x0.23x35	16.1	
		2x0.18x6	2.16	
		2x0.3x60	36	
		2x0.20*9	3.6	
2.	Out side of Cable Celler	2x.23*160	73.6	
3.	Cable Celler (6 mtr.)	2x0.08x300	48	
		2x0.10x200	40	
4.	Transformer (switch yard)	2x0.23x18	8.28	
		<b>Total Area</b>	<b>326.2</b>	

For JSPL



For Multicle Fire Pvt. Ltd.

