

Measurement Certificate

Vendor: M/s. Multi Kilfire Pvt. Ltd. -Gujarat

Client: MECON Limited

Location: Visakhapatnam Steel Plant

PO. No. : 28.01.123C/Passive Fire Protection/05, Dt. 07-08-2018


Site: WRM-2 At RINL, VSP, Visakhapatnam, AP

S.NO	Description of Items	Unit	Qty as per W.O.	Claimed by Agency	Certified by MECON Site Engineer
1	Sealing of conduits (Avg 150mm dia) including supply of all materials required for sealing job	Nos.	100	100	100
2	Supply and application of Fire Retardant paint on Cables (Aprox. 1500 cables will be painted at two locations)	Kg	500	500	500
3	Passive Fire protection wall for floor closing at 5.5mtrs level in ECR-1 as per requirement with fire sealing compound including supply of all material. Thickness of fire barrier shall be as per the site requirement (aprx 100mm)	Nos.	80	80	80
		Nos.	20	20	20

Job Commencement:

Job Completion: 12-09-2018

For MECON Limited


G. Sathiraju
Manager (Electrical)
MECON Limited
Visakhapatnam Steel Plant
Visakhapatnam - 530001