

Dt. 09.03.2019

MINUTES OF MEETING BETWEEN M/s TATA CHEMICALS LTD. AND M/s MULTIKILFIRE

Sub : Application of 750 Kg. quantity of Fire Retardant coating on electrical cables at cement plant substations, coal mill area and locations on cable trays having cable joints as per P.O. No. 4910011291 dated 24.01.2019

Jobs attended during the visit :

Cleaning of cables and applying fire retardant coating at following locations:

- 1. Cooler ESP TR set cables**
- 2. HT cable joints at MSS-1 and Hathi Channel cable bridge**
- 3. New HT cables for MSS-2 6.6KV board, HT VFDs at MSS-2, 6.6KV ring mains between MSS-1 & MSS-2, New HT cables for new lime stone crusher, Alkali bypass Baghouse VFD cables**
- 4. All cables at New Coal Mill and Old Coal Mill**

M/s TCL has requested M/s Multikilfire to provide technical details regarding thickness of coating and retention time.

Representatives of M/s Multikilfire have completed the job safely without any deviation.


20/9/3/19

Mr. Bhavesh B. Mehta

(M/s TCL)


09/03/19

Mr. Ramsingh

(M/s Multi Kilfire)