

Minutes of meeting held between M/s. Multi Kil fire & M/s. Tata chemicals Ltd.

Mr. Ram Singh of M/s. Multikil Fire Pvt. Ltd. Reached at site on 5/9/2014 with his team of 5 members. Application of fire coating at turbine floor area and fire barrier at various substations have been done during their visit against following POs.

Sr. No	Job	Qty.	PO no
1	Installation of Fire coating	500 KG	PO/2014-15/46/083 Dt. 23.08.2014
2	Installation of Fire Barrier	160 Sq. Mtr	PO/2014-15/46/083 Dt. 23.08.2014
3	Installation of Fire Barrier	40 Sq. Mtr	Additional PO

Fire barrier installation work done in following sub stations.

Sr No	Plant / Location	Substation	Qty in Sq. Mtr	Remarks
1	CCG	RO substation	23.14	
2	CCG	CCD	23.14	
3	SA	NDA	8.00	
4	SA	CT-5	3.14	
5	SA	MHY	3.14	
6	MUW	MUW-2AR	31.25	
7	Kiln	Kiln Substation	23.14	
8	Kiln	MUW-3	35.06	
9	Cement	MSS-1	6.00	
10	Cement	SS 3	6.00	
11	Cement	ESF	38.00	
Total			200.01	


Mr. Ramsingh and team will leave site on 18/10/2014.

For M/s. Tata Chemicals

Mr. D. K. Chanpa


18/10

Mr. Chirag Parmar


18/10/14

For M/s. Multikil

Mr. Ram Singh


18/10/14