



Date: 24/6/14

WORK COMPLETION REPORT

As per our PO. 51000, five Retardant paint coating and five barrier work completed at our Bankbay & Co premises for all underground cables in GIS.

Total 515kg KF-600 paint applied &
3400kg KF-604 fire barrier blocks used.

Work completed successfully on 24/6/14.



Sandeep Mohan.
(EHV CABLES)
SANDEEP MOHAN.

TATA POWER

The Tata Power Company Limited

Western Region Projects, Dharavi Receiving Station Matunga Mumbai 400 019

Telefax 91 22 6666 8236

Registered Office Bombay House 24 Homi Mody Street Mumbai 400 001