






ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
P. B. 760, ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India. Gram : ELECSEARCH
EPABX : +91 (0265) 2642942, 2642964, 2642377, 2642557, 2635300, 2635253, 2657784, 2657785.
Fax : +91 (0265) 2638382. E-mail : erda@erda.org , dir@erda.org , adir@erda.org



TEST REPORT		
SHEET 1 of 2		
NAME & ADDRESS OF CUSTOMER M/s Multi Kilfire Pvt Ltd., 4, Amin Industrial Estate, Gorwa Road, Vadodara-390 016.	REPORT NO. :	ICWRWO0051564
	DATE :	15-06-2007
	CUSTOMER REF NO :	MKPL/ERDA/101
	DATED :	02-06-2007
	DATE OF SAMPLE RECEIPT	DATE OF TESTING
	02-06-2007	15-06-2007
SAMPLE DESCRIPTION		SAMPLE IDENTIFICATION
1 Core x 240 Sq.mm Flexible rubber cable coated with Fire Retardant Coating KF 600. Flexible Tinned copper conductor, EPR Rubber insulation and overall PCP Rubber sheath.		
Sr. No.	TEST DETAILS	TEST SPECIFICATION
1.	Flame Test (Burlap method)	IEEE 383-1974
REMARK : The sample conforms to the requirement for the above mentioned test. NOTE : The above test was conducted in the presence of Mr.Sanjay Patil (M/s Suzlon), Mr.Jaykumar and Cmmdr. Ramanan from M/s Multi Kilfire Pvt Ltd., Vadodara.		
<p style="text-align: center;">  PREPARED BY </p> <p style="text-align: center;">  CHECKED BY </p> <p style="text-align: right;">  APPROVED BY </p>		
NOTE: 1. This report relates only to the particular sample received for testing in good condition at ERDA. 2. This report cannot be reproduced in part under any circumstances. 3. Publication of this report requires prior permission in writing from Director, ERDA. 4. Only the test asked for by the customer have been carried out.		

No: 1652876






ELECTRICAL RESEARCH AND DEVELOPMENT ASSOCIATION

(Accredited by the National Accreditation Board for Testing and Calibration Laboratories, Govt. of India)
P. B. 760, ERDA Road, Makarpura Industrial Estate, Vadodara-390 010, India. Gram : ELECSEARCH
EPABX : +91 (0265) 2642942, 2642964, 2642377, 2642557, 2635300, 2635253, 2657784, 2657785.
Fax : +91 (0265) 2638382. E-mail : erda@erda.org , dir@erda.org , adir@erda.org



REPORT NO : ICWRWO0051564				SHEET 2 of 2	
DATE : 15-06-2007					
Sr. No.	Cl. No.	Tests	Requirement as per Specification	Obtained value	Remarks
1.	2.5	Flame Test (Burlap method)	The cable shall not propagate the flame and burn up to the total height of the tray from the flame source.	Sample did not burn up to the total height of the tray from the flame source.	Conforms
P. J. Patel PREPARED BY			 CHECKED BY		

Nº 1652877

