

MKPL/12-13/
30.07.12


Sub: Verification and testing of material by Lloyds Register Asia for supply to BHEL
Project: 1 x 67.5 MW Vizag Cpp
PO No: PW/PE/PG/VZG/P-985/11 dt. 19.03.12

The following tests were conducted and verified :

1. Fire Stop Sealing system (KF-604)
 - a. Bulk Density Verified/passed
 - b. Fire rating CBRI Certificate submitted

2. Fire Retardant Coating (KF-600)
 - a. Water Resistance Verified/passed
 - b. Fire Propagation test Verified/passed

For Multi Kilfire Pvt. Ltd.,



Shashwath Jayakumar
Executive Director



For Lloyd's Register Asia

